

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7270-0085:192 Page 1 of 1

CATEGORY: Heat Detector

LISTEE: ADT Security Services, Inc., 4128 North Freeway Blvd., Sacramento, CA 95834-1219
Contact: Ron Dalton (310) 725-2972 Fax (310) 725-2942*

DESIGN: Models 5351ADT (fixed temperature) and 5351RADT (fixed temperature with Rate-of-Rise) electronic heat detectors. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 135° F fixed temperature

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical ratings, and UL Inc. Label

APPROVAL: Listed as heat detectors for use with Model B501 or B710LP base (CSFM Listing No. 7300-0028:173) and listee's separately listed compatible fire alarm control units.

XLf: 7270-0028:196

*Rev. 06-08-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 8, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager